

# Roofing Addendum

## March 23, 2023

### Questions and **Answers**

1. Is the current lightning rod system UL Certified?
  - **Yes, it is and the UL plate is located on the circuit breaker box inside the township building.**
2. Are other shingles and certifications able to be bid?
  - **Yes. As per the bid specs, other shingles and certifications are allowed, it is just up to the bidder to supply the verification that the proposed items and certifications are equal to, or better, than the Certainteed 5 star certification and the shingles shall be equal to or better than CertainTeed Landmark PRO Dimensional asphalt fiberglass roofing shingles.**